



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00761

OWNER'S NAME: CATLIN

DATE: 5/6/2016

TYPE: Insulation

TIME STARTED: 10:36 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-06090-0007

1. Provide vapor barrier @ master shower (Do not cover this area)
2. Gas piping @ 14# - Needs to be 15#/15 mins
3. Fireplace rough in Ok
4. Permit Card Not On Site - Let CDS Office Know if a Replacement is Needed

**INSTRUCTIONS:** Permit must be on site @ all times/Do not cover master shower/Install vapor barrier/Gas pressure/Re-Inspection

**NEXT INSPECTION:** Re-Inspection

**RE-INSPECTION FEE DUE?**



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506