



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00779

OWNER'S NAME: SHILLEY

DATE: 9/29/2016

TYPE: Final

TIME STARTED: 11:31 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-03010-0014

1. Truss bolting approved by Lou 9-28-16
2. Bottom cord truss correction per JC 7-14-16 crossed out?
3. Rear roll up door not installed

INSTRUCTIONS: Confirm correction from 7-14-16/Complete rear door installation

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506