



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00798

OWNER'S NAME: ZIEGLER

DATE: 6/17/2016

TYPE: Rough-in plumbing

TIME STARTED: 1:06 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29051-0094

1. Plumbing rough in Ok
2. Supply live - Ok
3. DWV on stack - Ok
4. Fireplace rough in Ok
5. Draftstop complete - Ok
6. Provide engineer fix for HD @ pocket door in kitchen (on 2 trimmers)
7. House hydronics not on test
8. Gas @ 6# - Needs to be 15#/15 mins

INSTRUCTIONS: Complete above corrections

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506