



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00798

OWNER'S NAME: ZIEGLER

DATE: 7/1/2016

TYPE: Insulation

TIME STARTED: 11:23 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29051-0094

1. Insulation ok
2. Hydronics not on test due to hole in line. Can be seen before cover

INSTRUCTIONS: Ok to cover interior. Hydronics to be seen prior to floor cover

NEXT INSPECTION: Hydronics

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506