## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00805	OWNER'S NAME:	CROWLEY
DATE:	1/6/2017	TYPE:	Mechanical and plumbir
TIME STARTED:	3:15 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	20-17-32056-0003		
<ol> <li>PLUMBING DWV TEST PLUGS NOT ABLE TO HOLD SUFFICIENT PRESSURE FOR TEST. Test P ressure to Be Confirmed at Future Inspection.</li> <li>Plumbing Supply Test OK. 70#/15min. OK.</li> <li>Mechanical Rough In OK.</li> <li>Fireplace Rough In OK.</li> <li>Kitchen Range Vent Duct to Be Insulated Prior to Cover.</li> </ol>			
INSTRUCTIONS: OK to Call fro Framing Once L&I Inspection has Been Passed.			
NEXT INSPECTION: Framing			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  ADDRESS: <u>ieremv.haberman</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694 <a href="http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx">http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx</a>			

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506