



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00805

OWNER'S NAME: CROWLEY

DATE: 1/19/2017

TYPE: Rough-in plumbing

TIME STARTED: 12:17 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-17-32056-0003

1. DWV on Test OK. 5#/15min. BOTH HALVES OF STRUCTURE.

INSTRUCTIONS: OK to Cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506