



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00816

OWNER'S NAME: REYKDAL

DATE: 11/16/2015

TYPE: Mechanical

TIME STARTED: 4:20 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-02054-0022

	1. Kitchen Range Vent OK. Functioning Verified.

INSTRUCTIONS: Schedule Remaining Plumbing Inspection

NEXT INSPECTION: Plumbing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremv.haberman@co.kittitas.wa.us](mailto:jeremv.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506