



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00858

OWNER'S NAME: GARDNER

DATE: 7/18/2016

TYPE: Floor framing

TIME STARTED: 12:07 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-19-12000-0002

1. Approved Permit Set Plans Onsite.
2. Floor Framing OK.
3. EXTERIOR PORCH FOOTINGS AND PIERS NOT APPROVED. REBAR MATS NOT SEEN. DO NOT POUR.

INSTRUCTIONS: DO NOT POUR PORCH FOOTINGS WITHOUT INSPECTION. OK TO SHEET FLOOR.

NEXT INSPECTION: PORCH FOOTINGS.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506