



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00858

OWNER'S NAME: GARDNER

DATE: 9/9/2016

TYPE: Mechanical and plumbir

TIME STARTED: 10:29 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-12000-0002

1. Supply @ 60#/15 mins - Ok
2. DWV on Stack - Ok
3. Plumbing RI Ok
4. Mechanical Exhaust Ok
5. HVAC AHU not installed @ time of inspection
6. NOTE: L&I Inspection must be completed prior to Framing Inspection

INSTRUCTIONS: Verify AHU installation next inspection/Complete L&I inspection

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506