



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00921

OWNER'S NAME: WT DEVELOPMENT

DATE: 3/4/2016

TYPE: Exterior shear

TIME STARTED: 11:20 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-31077-0002

1. Portal frame at garage not per plan. Follow ALL guidelines of detail on page A7.
2. All other shear ok
3. Headers do not extend over portal frame

INSTRUCTIONS: Ok to cover all but garage front. Re-inspect this area

NEXT INSPECTION: Re-inspect portal frame on garage, plumb/mech

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jessica.contratto @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506