



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00921

OWNER'S NAME: WT DEVELOPMENT

DATE: 3/29/2016

TYPE: Insulation

TIME STARTED: 12:16 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-31077-0002

1. Gas at 30#-ok
2. H2O at 85#-ok
3. Still awaiting engineer fix for portal frame
4. Porch footings to be seen before pour

INSTRUCTIONS: Ok to cover all except garage front area. See footings before pour

NEXT INSPECTION: portal frame/footings

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506