



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00921

OWNER'S NAME: WT DEVELOPMENT

DATE: 4/12/2016

TYPE: Footings

TIME STARTED: 12:34 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-31077-0002

1. Porch footings 24x24x12 w/ (4) #4 EW and (4) #4 verts
2. Footings not per dwgs
3. Provide engineer letter for revision
4. Pour at your own risk
5. Portal frame correction still outstanding
6. DWV correction still outstanding

INSTRUCTIONS: Pour @ your own risk/Provide engineer approval for observed installation above or install per drawings

NEXT INSPECTION: Re-Inspection (DWV)

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506