



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00921

OWNER'S NAME: WT DEVELOPMENT LL

DATE: 4/14/2016

TYPE: Multiple (see notes)

TIME STARTED: 10:57 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-31077-0002

1. Pads are 24x24x12 per last inspection - engineer letter calls for 30x30x10
2. Provide picture of forms per engineer letter
3. Ok to pour once revised
4. DWV still not on test

INSTRUCTIONS: Provide picture of corrected forms/Ok to pour once corrected

NEXT INSPECTION: DWV

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506