



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00923

OWNER'S NAME: SENER

DATE: 5/25/2016

TYPE: Final

TIME STARTED: 1:04 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-16-07059-0001

1. Complete set of plans not on site. Only site plan
2. Hydronic heat system being installed. Mechanical permit must be issued
3. No evidence of WUIC inspection?
4. Building has been spray foam insulated without framing approval

INSTRUCTIONS: complete above, pay re-inspection fee

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jessica.contratto @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506