INSPECTION REPORT

INST ECTION REFORM			
PERMIT NUMBER:	BP-15-00928	OWNER'S NAME:	SMITH
DATE:	11/9/2016	TYPE:	Slab
TIME STARTED:	2:54 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	17-18-22010-0026		
 Garage Floor OK to Pour Exterior Porch Piers OK to Pour. NOTE: Residence Slab Not Ready to Pour. Thickened Footing bar not complete. R adiant Tubing Not Complete. Slab Insulation Not Complete. 			
instructions: Ca	all for inspection when ready.		
NEXT INSPECTION: Radiant??			
RE-INSPECTION FEE DUE? V NO YES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: <u>ieremv.haberman</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506