



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00928

OWNER'S NAME: SMITH

DATE: 11/15/2016

TYPE: Slab insulation

TIME STARTED: 4:16 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-22010-0026

1. Slab Insulation OK. R-20 Installed
2. Fresh Air Intake For MASONRY Fireplace OK.
3. Thickened Footings OK.
4. NOTE: Hydronic Tubing Not Ready For Inspection.

INSTRUCTIONS: Call for Hydronic Inspection When Ready

NEXT INSPECTION: Hydronic

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506