



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00037

OWNER'S NAME: YOUNG

DATE: 11/8/2016

TYPE: Plumbing

TIME STARTED: 2:17 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-14-02050-0002

1. Plumbing Rough In OK. DWV on Stack Test. Supply at 50#/15min OK.
2. Mechanical Exhaust OK.

INSTRUCTIONS: OK to Cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506