



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00079

OWNER'S NAME: DUNCKLEY

DATE: 10/21/2016

TYPE: Framing

TIME STARTED: 9:49 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-34053-0104

1. Install clips on southside trusses in bedroom 2
2. Corrections Ok
3. Framing Ok
4. NOTE: Exterior stair not complete @ time of framing inspection

INSTRUCTIONS: Complete correction above/Ok to insulate/Verify exterior stair framing @ insulation

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506