



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00079

OWNER'S NAME: DUNCKLEY

DATE: 10/28/2016

TYPE: Insulation

TIME STARTED: 12:09 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-34053-0104

1. Truss clips Ok
2. Rear stair framing not complete
3. Insulation Ok

INSTRUCTIONS: Ok to cover

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506