



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00095

OWNER'S NAME: DK PROFESSIONAL

DATE: 4/26/2016

TYPE: Framing

TIME STARTED: 12:49 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12058-0023

1. Gas @ 25#/15 mins - Ok
2. Draftstop Ok
3. Trusses Ok
4. Front deck ledger nailed - drawings call for (2) SDS @ 16" OC
5. Deck ledger does not have lateral load connection per detail D2/S6

INSTRUCTIONS: Make corrections above/Ok to insulate/Verify corrections @ insulation

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506