



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00121

OWNER'S NAME: HORSE CANYON RANCH

DATE: 3/30/2016

TYPE: Gas piping

TIME STARTED: 10:55 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-17-32040-0005

1. Permit card not on site
2. Gas pipe cannot penetrate foundation walls below grade. See code page printed out
3. Gas line to firepit at 16#-ok
4. Gas line from foundation penetration to bbq at 50#-ok. Ok to bury line from bbq up to the deck penetration. Line will be retested when corrected at deck

INSTRUCTIONS: Complete correction

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jessica.contratto @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506