



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00144

OWNER'S NAME: AMICK

DATE: 12/29/2016

TYPE: Mechanical and plumbir

TIME STARTED: 2:37 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-19020-0006

1. Mechanical Rough In OK.
2. Plumbing Rough In OK
3. Plumbing Not On Test. Provide DWV and Supply Test at Framing Inspection.
4. Fireplace Rough In Not Approved. Draftstop Not Complete.

INSTRUCTIONS: OK to Call for Framing When Ready

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506