INSPECTION REPORT

PERMIT NUMBER:	BP-16-00144	OWNER'S NAME:	AMICK
DATE:	1/17/2017	TYPE:	Framing
TIME STARTED:	12:29 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-14-19020-0006		
1. Framing ok 2. Truss bracing 3. Clips needed 4. DWV at 5#-ok 5. H20 at 70#-ok 6. Draftstop ok 7. Exhaust ducti	on every truss on exterior walls		
INSTRUCTIONS: Ok to insulate			
NEXT INSPECTION:	Insulation		
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: <u>iessica.contratto</u> @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506