



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00192

OWNER'S NAME: NORTHLAND INVESTM

DATE: 6/7/2016

TYPE: Shearwalls

TIME STARTED: 10:26 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-26063-0005

1. Joist Hanger Correction From Floor Framing Inspection OK.
2. Thru Access In Crawl Space Correction Outstanding.
3. Shearwall Alternate at Dining Room Slider Door OK per Engineer Notated 2 of 7
. Drawing Saved to T Drive.
4. Enlarged Opening at Dining Room Slider Approved Per Engineers Drawing.
5. Window over Shower in Bathroom between Bedrooms 2 and 3 OK per Engineers Letter.
6. Pony Wall Under Floor Between Foundation Wall and Shearwall Above Not Detailed in the plan. Provide Engineers OK.

INSTRUCTIONS: DO NOT COVER PONY WALL BELOW FLOOR WHERE CORRECTED CONDITION OCCURS.

NEXT INSPECTION: SHEAR REINSPECT.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506