



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00224

OWNER'S NAME: BOURNE

DATE: 3/2/2017

TYPE: Mechanical

TIME STARTED: 1:45 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-16-05030-0010

1. Gas @ 28#/15 mins - Ok
2. Supply @ 80#/15 mins - Ok
3. DWV @ 6#/15 mins - Ok
4. Plumbing RI Ok
5. Exhaust Fans Ok
6. HVAC Supply and Return Ok
7. Confirmed Fresh Air intake into RA
8. Soffit trusses Ok - Ok to cover soffits
9. Corrections Ok

### INSTRUCTIONS:

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506