INSPECTION REPORT

PERMIT NUMBER:	BP-16-00232	OWNER'S NAME:	BACK COUNTRY RESC
DATE:	12/5/2016	TYPE:	Final
TIME STARTED:	10:44 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	19-15-07061-0010		
 Caulk exterior penetrations (HP/BBQ gas line/Gas Meter) Maintain fire separation @ garage wall Step @ garage man door exceeds 7.75" Kitchen faucet not installed Exhaust fan not installed in Master Bathroom Maintain fire separation in mechanical room @ duct (OA & RA) Supply HVAC Main not insulated in crawl space Floor not insulated (Insulation Certificate shows R-30 see picture) Debris in crawl space Vapor barrier not installed in crawl space Blower door Ok FLS Ok Fireplace Ok Energy Credits Ok Only (6) foundation vents installed - (9) required per dwg INSTRUCTIONS: Complete above corrections/Re-Inspection			
NEXT INSPECTION: Re-Inspection			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
ADDRESS: <u>iustin.bennett</u> @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506