



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00232

OWNER'S NAME: BACK COUNTRY

DATE: 12/13/2016

TYPE: Re-inspection

TIME STARTED: 1:27 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-15-07061-0010

1. Fire separation in garage - wrap stud pack or complete rocking wall
2. Insulate supply duct in crawl
3. Complete floor insulation
4. Complete foundation vent installation
5. Other corrections Ok
6. RE FEE

INSTRUCTIONS: RE FEE/Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506