



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00249

OWNER'S NAME: COVEY

DATE: 5/1/2017

TYPE: Re-inspection

TIME STARTED: 2:07 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-15-08051-0004

1. C1 Modified trusses in garage - no letter on site
2. C3 4x6 Hem #1 (1) location in Master Bedroom @ window - not complete
3. Fireplace installation not complete

INSTRUCTIONS: Complete above/Re Inspection/DO NOT INSULATE

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506