INSPECTION REPORT

PERMIT NUMBER:	BP-16-00261	OWNER'S NAME:	FORTUNE CREEK LLC
DATE:	8/26/2016	TYPE:	Mechanical and plumbir
TIME STARTED:	11:02 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	19-15-07061-0011		
 DWV on stack-ok Gas at 25#-ok H20 is live Fireplace rough in ok Staple plastic behind fireplace Exhaust ok 			
INSTRUCTIONS:			
NEXT INSPECTION:	Framing		
RE-INSPECTION FEE DUE? VES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: <u>iessica.contratto</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694 http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			