



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00261

OWNER'S NAME: FORTUNE CREEK LLC

DATE: 12/13/2016

TYPE: Final

TIME STARTED: 12:58 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-15-07061-0011

1. Caulk exterior penetrations
2. (2) Foundation vents installed - (6) required
3. Maintain fire separation in Mech Rm
4. Dishwasher not connected to waste in kitchen
5. Range hood not connected
6. HVAC supply not insulated
7. Floor insulation fall down in places
8. Blower door not on site
9. Fireplace not functional
10. Install electrical trim in great room
11. Sink in master suite leaks
12. Install outlet in upstairs bathroom
13. Confirm energy credits
14. Dryer vent Ok

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506