



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00298

OWNER'S NAME: WT DEVELOPMENT

DATE: 7/12/2016

TYPE: Exterior shear

TIME STARTED: 9:08 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-31070-0002

1. Provide panel edge blocking/nailing at ABWP next to garage exterior man door
2. Exterior shear ok
3. Straps at interior of portal frame areas to be seen later

INSTRUCTIONS: Complete above, ok to cover

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL

ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506