



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00298

OWNER'S NAME: WT DEVELOPMENT

DATE: 8/12/2016

TYPE: Mechanical and plumbir

TIME STARTED: 8:57 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-31070-0002

1. Exterior Shear corrections not complete
2. Supply @ 80#/15 mins - Ok
3. DWV @ 5#/15 mins - Ok
4. Plumbing RI Ok
5. Mechanical RI Ok
6. Gas @ 21#/15 mins - Ok

INSTRUCTIONS: Complete Exterior Shear corrections

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506