



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00324

OWNER'S NAME: FITTERER

DATE: 6/21/2017

TYPE: Multiple (see notes)

TIME STARTED: 10:37 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-18-31000-0001

1. Complete roof sheathing blocking @ panel edge for Entry & Porch (Sheet 8)
2. Install clips on every truss per sheet 8
3. Install (2) bolts @ beam to beam connection right of entry (clouded on S8)
4. Install strap from beam to stud in Master Bedroom (Sheet 8)
5. Provide truss manufacturer fix/approval for A03 through A07 attachment to girder
6. Provide ledger attachment per sheet 6 (4) @ 16" OC
7. Gas @ 15#/15 mins - Ok
8. DWV on Stack - Ok
9. Supply Live - Ok
10. Plumbing RI Ok
11. Mechanical Ok
12. SA & RA Ok
13. OA confirmed

INSTRUCTIONS: Complete above/Verify @ insulation

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506