## **INSPECTION REPORT**

PERMIT NUMBER:	BP-16-00340	OWNER'S NAME:	KELLEY
DATE:	7/12/2016	TYPE:	Footings
TIME STARTED:	9:16 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	18-17-36051-0007		
<ol> <li>Setbacks Ok</li> <li>Strip Footings not formed in (2) locations (clouded on dwgs S2.1)</li> <li>Install (4) 36x36x10 footings w/ (5) #4 EW per notes on S2.1</li> <li>DO NOT POUR</li> </ol>			
instructions: De	O NOT POUR/Make corrections a	above/Re-Inspection	on
NEXT INSPECTION: Re-Inspection			
RE-INSPECTION FEE			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION  QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			

**INSPECTION REQUEST LINE: 509-962-7694** 

ADDRESS:\_

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506

iustin.bennett @co.kittitas.wa.us