



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00381

OWNER'S NAME: HANSON

DATE: 12/5/2016

TYPE: Multiple (see notes)

TIME STARTED: 12:17 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-16-26054-0003

1. Exhaust Ok
2. Supply Live - Ok
3. DWV @ 0# - needs to be a min of 5#/15 mins
4. Stamped drawings not on site - Framing inspection not performed
5. NOTE: Bring office copy of dwgs for framing inspection

INSTRUCTIONS: Bring office dwgs for framing inspection/Place DWV on test

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506