



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00381

OWNER'S NAME: HANSON

DATE: 12/12/2016

TYPE: Insulation

TIME STARTED: 11:14 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-16-26054-0003

1. Rafters Not Vented.
2. DWV Not On Test.

INSTRUCTIONS: DO NOT COVER. DO NOT HANG DRYWALL. Make Corrections Above. Call for Inspection When Ready.

NEXT INSPECTION: Re Inspection.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506