



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00404

OWNER'S NAME: HOUSER

DATE: 6/19/2017

TYPE: Rough-in plumbing

TIME STARTED: 8:20 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-36050-0411

1. Complete nail plate installation - multiple locations
2. DWV on Stack - Ok
3. Supply @ 70#/15 mins - Ok

INSTRUCTIONS: Complete nail plate installation (indicated w/ red on studs)/Verify @ Mech

NEXT INSPECTION: Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506