## **INSPECTION REPORT**

PERMIT NUMBER: BP-16-00425 OWNER'S NAME: HUTCHENS

DATE:	10/28/2016	TYPE:	Gas piping
TIME STARTED:	10:06 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-15-29050-0030		
1. Gas @ 22#/15 mins - Ok			
INSTRUCTIONS:			
NEVT INSPECTION.			
NEXT INSPECTION:	Plumb/Mech		
RE-INSPECTION FEE DUE? VES \$  IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
ADDRESS: <u>iustin.bennett</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694  http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			