



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00425

OWNER'S NAME: HUTCHENS

DATE: 12/8/2016

TYPE: Mechanical and plumbir

TIME STARTED: 1:15 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29050-0030

1. Mechanical signed of 11/18/16 by JC
2. Fireplace draftstop Ok
3. DWV @ 4# - needs to be a min of 5#/15 min
4. Supply @ 78#/15 mins - Ok
5. Plumbing RI Ok

INSTRUCTIONS: Pressurize DWV/Verify @ Framing

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506