INSPECTION REPORT

PERMIT NUMBER:	BP-16-00444	OWNER'S NAME:	DK PROFESSIONAL
DATE:	1/5/2017	TYPE:	Rough-in plumbing
TIME STARTED:	1:00 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-14-12068-0005		
1. DWV at 5#-ok 2. Gas at 15#/15-ok 3. H20 at 50#-ok			
INSTRUCTIONS:			
NEXT INSPECTION:	Frame/mech		
RE-INSPECTION FEE			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
ADDRESS:iessica.contratto @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			
http://www.co.kittitas.wa.us/cds/huilding/inspection-request aspy			

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506