



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00458

OWNER'S NAME: SUNCADIA

DATE: 7/15/2016

TYPE: Gas piping

TIME STARTED: 2:54 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-23050-0013

1. Gas Piping On Test 20#/15min. OK.
2. Photos on 'T' Drive
3. Your next inspection is the final inspection and must be scheduled, passed and approved within one (1) year of this date. Failure to pass a final inspection within one (1) year will cause the permit to expire per KCC 14.04.070.

INSTRUCTIONS: Call for Final Once Appliance is Installed

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506