



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00487

OWNER'S NAME: CARNEY

DATE: 5/2/2017

TYPE: Framing

TIME STARTED: 11:16 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-20-32000-0008

1. Plumbing RI Ok - nail plates installed
2. Gas @ 5# - Needs to be 15#/15 mins
3. Truss A01 has different web configuration than installed - provide accurate truss sheets
4. Truss B02 does not have bracing - clouded on truss sheets
5. Clip trusses @ bearing wall in kitchen
6. Provide glulam header @ utility room per dwgs
7. Provide (2) 2x10 @ bearing wall at loft - clouded
8. Provide 3 1/8"x 11-1/4" GLB @ E Roof Framing - clouded on dwgs
9. Attic Access not framed
10. Provide 5-1/8"x 11-1/4" GLB above dining - clouded on dwg
11. Complete nailing truss clips - throughout
12. Provide straps @ all beam breaks
13. Provide adequate bearing @ all beams
14. Provide draftstop @ fireplace
15. Provide installation manual for fireplace - not found on site

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00487

OWNER'S NAME: CARNEY

DATE: 5/2/2017

TYPE: Framing

TIME STARTED: 11:16 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-20-32000-0008

Page 2

16. Provide clips or equivalent @ truss midpoint bearing on south porch

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506