



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00487

OWNER'S NAME: CARNEY

DATE: 5/8/2017

TYPE: Re-inspection

TIME STARTED: 3:20 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-20-32000-0008

1. Corrections OK.
2. Mechanical Exhaust Duct Work Not Installed. Must Be Seen by Insulation.

INSTRUCTIONS: OK to Insulate.

NEXT INSPECTION: Insulation/ Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506