



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00501

OWNER'S NAME: COSTA

DATE: 11/30/2016

TYPE: Plumbing

TIME STARTED: 11:19 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-13000-0001

1. DWV on Stack - Ok
2. Supply Live - Ok
3. Plumbing RI Ok
4. Mechanical Exhaust Ok
5. Complete HVAC supply insulation
6. Range vent will need to be insulated

INSTRUCTIONS: Complete above/Complete L&I inspection/Verify corrections next inspection

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506