



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00546

OWNER'S NAME: BUILDWORX

DATE: 7/13/2017

TYPE: Insulation

TIME STARTED: 9:56 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 22-11-04053-0904

1. Framing corrections not complete - see 6/26/17 Framing Report
2. Wall Insulation - Batt w/ vapor barrier
3. Rafters - Batt
4. Floor - Batt
5. NOTE: Provide container of PVA Primer
6. Above Grade Hydro @ 100#/15 mins (3) manifolds - Ok

**INSTRUCTIONS:** Complete fire blocking per correction/Ok to cover other areas

**NEXT INSPECTION:** Fire Blocking

**RE-INSPECTION FEE DUE?**



NO



YES

\$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506