INSPECTION REPORT

PERMIT NUMBER:	BP-16-00570	OWNER'S NAME:	SAVIDGE
DATE:	11/23/2016	TYPE:	Mechanical and plumbir
TIME STARTED:	9:05 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	17-19-06071-0001		
1. Mechanical Of 2. Supply @ 60# 3. DWV @ 5#/15 4. Plumbing RI Of 5. Trusses Ok 6. Framing Ok	½/15 mins - Ok 5 mins - Ok		
INSTRUCTIONS:			
NEXT INSPECTION:	Insulation		
RE-INSPECTION FEE	DUE? V NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
	ADDRESS:	iustin.bennett @	co.kittitas.wa.us
INSPECTION REQUEST LINE: 509-962-7694			
http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ● Main Office Line: 509-962-7506			