



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00571

OWNER'S NAME: GIRLING

DATE: 10/13/2016

TYPE: Footings

TIME STARTED: 2:16 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-14-21050-0001

1. Setbacks OK.
2. Slope Setback OK for Residence Footings.
3. NOTE: Future Deck Footings May Be Withing Clearance to Slope Boundry
4. Footings OK.
5. NOTE: Deck Footings Not Seen at this Time

INSTRUCTIONS: OK to Pour Residence Footings.

NEXT INSPECTION: Foundation Walls

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506