



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00571

OWNER'S NAME: GIRLING

DATE: 7/18/2017

TYPE: Exterior shear

TIME STARTED: 3:37 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-14-21050-0001

1. Exterior Shear Ok
2. Interior Shear Ok
3. Roof straps over beams Ok

INSTRUCTIONS: Ok to cover Exterior

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506