



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00582

OWNER'S NAME: ODELL

DATE: 1/23/2017

TYPE: Shearwalls

TIME STARTED: 1:48 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-33020-0028

1. Exterior Shear Ok
2. Deck soffit Ok - Ok to cover soffit only

### INSTRUCTIONS:

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506