



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00582

OWNER'S NAME: ODELL

DATE: 3/13/2017

TYPE: Mechanical and plumbir

TIME STARTED: 12:13 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-33020-0028

1. Exhaust Ok
2. HVAC Supply & Return Ok
3. HVAC unit not installed at time of inspection
4. DWV @ 6#/15 mins - Ok
5. Supply @ 85#/15 mins - Ok
6. Plumbing RI Ok
7. Gas @ 35#/15 mins - Ok

INSTRUCTIONS:

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506